

PANpilot pH Rx

Simultaneously regulates pH and chlorine or bromine levels (mV)

*Suitable for controlling an electrolytic cell or the dissolution of chlorine or bromine tablets.
For public pools, suitable for an attendance of 1 to 2 people / 10m³ / day.*

Private Pools

Public Pools

Hot tubs

AYPA1011



Scan to discover !



- pH** : 3L/h metering pump

pH

- Chlorine or bromine output: 230 VAC outlet with pre-wired power connections



Rx Cl/mV

- Panel dimensions : 58 x 38 x 15 cm

- Professional analysis chamber:
 - Turboxy® chlorine sensor
 - pH sensor
 - Flow switch
 - Sampling valve

Flw

INNOVATIVE

- PANpilot® simultaneously regulates pH and chlorine* or bromine levels.
- It simultaneously displays the redox value (chlorine content (mV)) and the pH value.
- The sensors are protected against induced electric currents in the water.

SAFE

- Volumetric alarm preventing the chemical container running dry.
- Dosage proportional to pH and chlorine requirements.
- Jack input connectors for detection of empty pH and chlorine containers.

COMPLETE

- Delivered with a **complete kit** installation for quick and easy :



VERSATILE

- Intended for public pools (up to 200m³, 1 to 2 people / 10m³ / day) and private pools (up to 300m³)
- Chlorination: select the appropriate chlorination method (electrolytic cell, dosing pump, solenoid valve).

WARRANTY

- Device: two years | Sensors: one year

**To ensure correct redox measurement, make sure that the stabiliser content in the pool does not exceed 15 ppm (15 mg/l).*

***Incompatible with hydrochloric acid*

AvadyConnect® Web Interface



By installing the **optional AVADYCONNECT® COMMUNICATION KIT**, this device will allow the user to remotely consult and control pool related data.



ADVANTAGE A single dashboard to remotely manage the maintenance of all your pools. You can now remotely change device settings, receive low level of product alerts, check data history and graphs etc.

Discover our web interface at www.avadyconnect.com; username and pw: demo

AYAC100524